

REPORT TO THE PENDLETON TOWN BOARD
For November, 2019, by Jeff Stowell/Sewer Superintendent

Sewer Department

- 15 Regular time sewer calls
- 8 Overtime sewer calls
- Rebuilt E-One pumps
- Installed hardware and pump in 2 new build grinder units
- Checked Duplex tanks and Lift Stations
- Met with reps from Siewert to discuss problems with E-One pumps

Water Department

- Looked for water leaks for 4 days with rep from Rural Water. Broken water line for water driven sump pump in pit at Tonawanda Creek and Transit. Water loss on a Town water line
- Repaired 4 Fire Hydrants
- 1 Service leak on Mapleton. Homeowner repaired
- 3 Compliance Inspections
- 10 Final reads
- Changed old Orion readers for house on Townline Rd
- Turned water off to seasonal users
- Install reader and inspect plumbing at Bob Cat of Buffalo
- Completed stage II water samples
- 81 Stakeouts completed