


TOWN OF PENDLETON
6570 Campbell Boulevard
Lockport, NY 14094



*Supervisor Joel Maerten
Councilman Jason Evchich
Councilman David Fischer
Councilman Justin Graham
Councilman David Leible*

At the regular meeting of the Town Board of the Town of Pendleton, Niagara County, New York, held in the Board Room at the Town of Pendleton Town Hall, 6570 Campbell Boulevard, Lockport, New York, 14094 at 7:00 p.m. on October 11, 2021.

WHEREAS, the Town of Pendleton has install and maintains fire alarm systems in Town-owned buildings; and

WHEREAS, an upgrade to the alarm monitoring systems is necessary; and

WHEREAS, an attempt was made to solicit three (3) quotes from reputable vendors of alarm monitoring systems installation and services was attempted and two (2) written quotes were provided to the Town; and

WHEREAS, quotes were received from Amherst Alarm for \$595.00 installation with \$418.00 per year monitoring and Armored Access for \$780.00 installation with \$37.00 per month monitoring, and

WHEREAS, Armored Access has most recently installed monitoring systems as well as a variety of computer networking components and the quality of service has been deemed high-quality and responsive, and

WHEREAS, it is determined that Armored Access is the most appropriate vendor of monitoring services and the relatively minor difference in cost is negligible compared to quality of service and responsiveness.

NOW, THEREFORE BE IT RESOLVED, by the Town Board of the Town of Pendleton on this 11th day of October 2021 that a contract with Armored Access is approved for \$780.00 alarm monitoring installation cost and \$37.00 per month monitoring for up to three (3) years. This resolution shall take effect immediately.

The above resolution was offered by _____, who moved for its adoption, and seconded by _____.

The following vote was taken and recorded as:

Aye

Nay


Supervisor Joel Maerten

Councilman Jason Evchich

Councilman David Fischer

Councilman Justin Graham

Councilman David Leible



ARMORED ACCESS

CAMERA & SECURITY SYSTEMS

Shield what matters.

July 28, 2021

Pendleton Town Hall

Fire System

- Upgrade The existing fire communicator to a new LTE internet and cellular communicator (the existing communicator runs off of two separate phone lines)

Total with wiring, equipment installation, testing, programming and training \$780*

*Phone lines will no longer be needed for the fire system

* Fire Alarm monitoring service rate is \$37/month based on 36-month agreement payable annually in advance (does not include annual fire test report)

Standard terms and conditions on Page "2" are part of this proposal



WATCHING OUT FOR WNY SINCE 1984

2361 Wehrle Drive
 Amherst, NY 14221
www.amherstalarm.com
 716-632-4600
 FAX 716-632-1156

FIRE ALARM PROPOSAL

Quote # AAAQ57837

Date 08/10/21

Sales Rep. Bob Adamek

Quote To:

Town of Pendleton
 Dave Leible
 6570 Campbell Blvd
 Pendleton, NY 14094-

davleible@aol.com

Phone : (716)870-7523

Mobile:

Here is the quote you requested.

System Location:

Town of Pendleton
 Dave Leible
 6570 Campbell Blvd
 Pendleton, NY 14094-

Sales Rep EMail

boba@amherstalarm.com

Site Phone: (716)870-7523

Qty	Description	Part Number	Location	Unit Price	Ext. Price
1	AES Fire Radio Transceiver with Full Data Report	AE-7788-F8RED		\$595.00	\$595.00
1	Back-Up Battery (12V 7aH)	DSC-BD712			
	Monitoring				
1	Fire Alarm Control Panel Monitoring Service via Anet Secure Monitoring Service with AES UL Listed Fire Transmitter including 24 test supervision per NYS Fire Code-\$418.00 per year plus tax, price not included in this quote.	AA-FACPMONAN ET		\$418.00	\$418.00
				SubTotal	\$595.00
				Sales Tax	\$0.00
				Total	\$595.00

NEW YORK STATE FIRE ALARM REQUIREMENTS

- * Fire Alarm / Life Safety Systems are required to be installed by New York State Licensed installation / service companies per New York State General Business Law Article 6D. Amherst Alarm, Inc. is licensed by New York State Department of State - License # 12000015868.
- * New York State Building / Fire Code Section 907.20 requires an annual test and inspection per NFPA 72 of Fire Alarm Systems. The initial test and inspection is included in this proposal.
- * New York State Building / Fire Code Section 907.15 requires that all systems be monitored for alarm and trouble conditions in an approved monitoring UL 827 central station. Amherst Alarm is UL Listed and FM Approved for fire alarm monitoring in our own facility.
- * Fire Alarm Monitoring requires either Two Phones Lines provided by customer or approved wireless transmission such as Anet Secure Transmitters per NFPA 72 - Chapter 8.
- * Fire Alarm Control Panels and Fire Alarm Power Supplies must be powered by hardwired dedicated 110VAC circuit provided by customer.