

REPORT TO THE PENDLETON TOWN BOARD
For April 2021, by Craig Walter/Sewer Superintendent

Sewer Department

- 17 Regular time sewer calls
- 9 Overtime sewer calls
- 4/24 had lift station failure at Pendale. Capacitors were bad in the “Add-A-Phase” causing both pumps to not run. Manholes flooded
- Completed lift station and duplex checks
- 3 Sewer line repairs
- Delivered recycle and refuse totes as needs
- New hire Lucas Frew started 4/26/21
- Topsoil and seed repairs

Water Department

- Checked no use/high use water meters
- Repaired 2 failed readers
- Drained ice rink
- Replaced leaking fire hydrant on Tonawanda Creek
- Inspected water/sewer open trench inspections
- 72 Stakeouts complete
- Completed compliance inspections as needed
- Completed Edmunds webinar
- Repaired leaking toilet at Town Hall
- Located water leak in Town Park